



District Level Water Analysis Laboratory, UPJN (Rural), Rampur

Water Analysis Report

Date of Report- 09-07-26

Report No-RMP/LAB/8/132

Report Issue :- Akal Academy Telipura

Address: Vill- Telipura, P.O Chaukhandi, Teh- Tanda, Rampur-244713

Ref. Letter No. A.A.T/veh/2026-27/192

Basic Detail Of Sample

District	RAMPUR	Block	Suar
Gram Panchayat	Telipura	Village	Telipura
Habitation	-	Location	School
Water Source	Hand Pump	Sample No.	8/26/07/P/01
Quantity of Sample	1000 ML(Normal And Acidic)	Date of S.C	07-07-26
Receiving Date	07-07-26	Sample Collector	Zahid Hussain
Sample Depositor	Zahid Hussain	Sampling Method	IS17614 (Part 1) : 2021
Analysis Start Date	08-07-26	Analysis End Date	09-07-26

MICROBIOLOGICAL PARAMETERS

S.No	Analysed Parameter	Unit	Observed Value	Specified Value As Per BIS 10500:2012		Reference Method Of Analysis
				Acceptable Limit	Permissible Limit	
1	E.Coli	CFU/100 ML	0	Shall not be detectable in any 100 ml sample	No Relaxation	IS 15185:2016
2	Total Coliform	CFU/100 ML	0			IS 15185:2016
3	Residual Free Chlorine	Mg/L	0	0.2	1	IS 3025 (Part 26)

[Signature]
(Microbiologist)

Laboratory Contact Detail-E-mail-habjalnigamgramin@gmail.com

NOTE: (1) This Certificate Refers Only to The Particular sample Submitted for Testing. (2) This Certificate Shall Not Be Reproduced Except In Full, unless written Permission for the Publication Of an Approved Abstract Has Been obtained From Head Of Laboratory (3) The Test Result Reported in This Certificate are Valid at The Time of And Under The Stated Conditions Of Measurements (4) Sample Will Be Stored Up to 7 Days (In case of Non Perishable items Only) From The Date of Issue.

Ballin
30/7/26

[Signature]
28/07/2026
AKAL ACADEMY TELIPURA
Vill. Telipura, P.O. Chaukhandi,
Teh. Tanda, Distt- Rampur (U.P.)
पञ्चायत मुख- 41444444: 41444444. 41444444



District Level Water Analysis Laboratory, UPJN (Rural)

14 MLT, STP, Suar Road, Ghatampur, Rampur



Test Report

Report Issued: Akal Academy Telipura, Village-Telipura, P.O. Chaukhandi, Teh-Tanda, Rampur-244713
Report No. RMP/LAB/161
Report Issue date 09.07.2026
URL NO. TC121922500000127F
Ref. Letter No. A.A.T/ueh/2026-27/192

Basic Detail of Sample			
Sample Name	Ground Water	Block	Swar
District	FAMPUR	Gram Panchayat	Telipura
Quantity of Sample	1000 ml	Village	Telipura
Preservation Type	Normal and Acidic	Location	School
Packaging Type	Plastic Bottle	Habitat	
Water Source	Deep tubewell	Date of Sampling	07.07.2026
Sample No.	C/26/07/192	Sample Collector	Zahid Hussain
Receiving Date	07.07.2025	Sampling Method	ISS025-part 4 (1987)
Sample Depositor	Zahid Hussain	Analysis End Date	09.07.2026
Analysis Start Date	07.07.2025	Humidity (50±15%)	57.4%
Environmental Condition (@25 ±3°C)	25.8°C		

Analysis Report					
S. No	Test Parameters	Unit	Specified Value as Per BIS 10500:2012		Reference Method Of Analysis
			Observed Value	Acceptable Limit	
1	pH (@25 ±3°C)	—	7.31	6.5-8.5	IS 3025(part 11):2023[Electrometric Method]
2	TDS	Mg/L	201	500	IS 3025(part 16):2023
3	Turbidity	NTU	0.0	1	IS 3025(part 10):2023
4	Colour	CU	<5	5	IS 3025(part 4):2021
5	Total Hardness (as CaCO3)	Mg/L	186	200	IS 3025(part 21):2023
6	Fluoride	Mg/L	0.272	1	IS 3025(part 21):2023
7	Total Alkalinity (as CaCO3)	Mg/L	174	200	APHA 24 th Edition 4506-F (Q) Electrode Method 2023
8	Chloride	Mg/L	21.5	250	IS 3025(part 23):2023
9	Calcium	Mg/L	44.4	75	IS 3025(part 32):1988
10	Magnesium	Mg/L	17.98	30	IS 3025(part 40):2024

Signature
Zahid Hussain
Analyst
Akal Academy Telipura, Village-Telipura, P.O. Chaukhandi, Teh-Tanda, Rampur (U.P.)
Lab. No. 26/07/192, School Code- 80031

Ballin
30/7/26



District Level Water Analysis Laboratory, UPJN (Rural)

14 MLT, STP, Suar Road, Ghatampur, Rampur



11	Nitrate	Mg/L	0.401	45	No Relaxation
12	Sulphate	Mg/L	7.40	200	400
13	Iron	Mg/L	0.00	1.0	No Relaxation

End of The Report

Prepared by
[Signature]
Reviewed by
[Signature]
Authorized Signatory
[Signature]



Ballin
30/7/26

Abbreviations - Mg/L-Milligram per liter, NTU- Nephelometric Turbidity units CU-Colour Unit, BD-below detection limit, VT-Not Tested

Remarks- The Tested Sample is Not Confirms Drinking Water Standard (in per IS 10500) with respect to our tested parameter Only.

- This Certificate is valid only for the Particular sample submitted for Testing.
- This Certificate shall not be Reproduced Except in Full, unless written Permission for the Publication of an Approved Abstract has been obtained from Head of Lab. -Rampur.
- The Test Result Reported in This Certificate are Valid at the Time of Aud Under the Stated Conditions of Measurement.
- Source is Verified by the Laboratory.

Signature
Zahid Hussain
Analyst
Akal Academy Telipura, Village-Telipura, P.O. Chaukhandi, Teh-Tanda, Rampur (U.P.)
Lab. No. 26/07/192, School Code- 80031

Annexure C

PERFORMA FOR THE SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

NO.

Dated:

It is certified that an inspection team headed by Ex. Rohit Kumar Sagar (SWSM)

(Name of Officers with Designation) from Assistant Engineer PHED

Inspected the Akal Academy Telipura, vill - Telipura, Chaukhandi, Rampur

(Name & Address of school) on 07/07/2026 (date of inspection) and on the basis of water

Test Report (Attached) bearing no. Rmp/LAB/161 dated 09/07/2026

or District Level Water Analysis Laboratory (PHED Lab) certified that the

Akal Academy Telipura (Name of school) has safe drinking water facilities for

The Students and members of the staff of the institution. School is also maintain the hygienic sanitation

Conditions in the school building & the campus as per norms prescribed by Central /State /U.T. Govt.

This certificate is valid till 08/07/2027

Signature with Seal

Name

Designation

Name & Address of the Office /Department

Rohit Kumar
AE Assistant Engineer
FWSM, Rampur (UP)

To

Akal Academy Telipura
vill - Telipura, c.o Chaukhandi
Teh - Tahra, Rampur
(Name & Address of the Institution)

Note: The certificate is to be Issued by authorized officer of PHED / local body / local authority

28 July 2026
PRINCIPAL
AKAL ACADEMY TELIPURA
Vill. Telipura, P.O. Chaukhandi,
Teh. Tahra, Distt. Rampur (U.P.)
Affiliation No. 2133836, School Code-80031

Balbir Singh
30/7/20